

PROJECT

PROJECT NAME

PROJECT REFERENCE (CLIENT)	XXXXXX
PROJECT REFERENCE (SUPPLIER)	E-XXXXXX
LOCATION	Huelva (Spain)
SITE	YYYYYYY
PLANT	AROMÁTICOS
UNIT	UNIFINING / PLATFORMING

VSIL - 1000 - XXXXXX

SIL VERIFICATION REPORT

Rev.	Date	Description	Created	Checked	Approved
0	21/05/2025	For comments	JS	PR	JB

1. OBJECTIVE & STANDARDS

The purpose of this report is the verification study of the Safety Instrumented Functions defined in the Process Hazardous Analysis (PHA).

The recommendations of the following Standards have been taken into account:

- IEC 61508:2010
- IEC 61511:2016
- ISA-S84

2. CALCULATIONS & VERIFICATION

As calculation tool "SILcet 8.0" has been used

The following three requirements of the IEC 61511/61508 has been checked:

- Systematic Capability (SIL certification or proven in use/prior use justification).
- Architectural Constraints (minimum redundancy) based on the routes of the Standards.
- Compliance of the PFDavg/PFH according with the Standards.

3. PROJECT INFORMATION

Project name:
Project description:

Safety Requirement Specification reference: SRS-1200-01

4. GENERAL DATA

The following general parameters have been used.

Parameter	Sensor subsystem	Logic Solver	Actuator subsystem
Operation mode	Low demand in all SIFs		
Life Time (LT)	15 years	15 years	15 years
MTTRDD	8 hours	8 hours	8 hours
Beta factor	5%	2%	10%
Proof test coverage (Cpt)	90%	95%	70%
Test interval (TI)	1 year	20 years	1 year
Start-up time	24 hours	24 hours	24 hours
PDC (high demand mode)	100%	100%	100%

MTTRDD: Mean Time To Restore (applicable to DD failures).

Beta Factor: for Common Cause Factor in redundant architectures (1oo2, 2oo3,...)

Cpt: Generic values if manufacturer data is not available.

TI: Test Interval showing the required frequency of proof tests.

Start-up time: used to calculate STR (Safe Trip Rate) and MTTFs (Mean Time To Fail Spuriously)

PDC (only for PFH): Partial Diagnostic Credit given to diagnostics of dangerous failures (depends on speed of automatic diagnostics versus demand frequency of the SIF). It considers DD failures that likely will not be converted to safe failures should be counted as DU failures.

5. VOTING DEGRADATION OF TRANSMITTERS

The most common voting scenarios utilized in the SIS are: One out of One (1oo1), One out of Two (1oo2), Two out of Two (2oo2), and Two out of Three (2oo3).

The following tables shows the configuration of the transmitters and the behaviour of the PLC on a Dangerous Detected Failure (DD). In this project the philosophy shown in Table 1 has been considered.

Table 1			PLC software			
Logic	Process Trip	Transmitter setting	Out of range diagnostic	Channel Trip	Architecture degradation	
					1st failure	2nd failure
1oo1	Low	Over Range	Yes	No	Alarm	--
1oo1	High	Under Range	Yes	No	Alarm	--
1oo2	Low	Over Range	Yes	No	1oo1	Process Trip
1oo2	High	Under Range	Yes	No	1oo1	Process Trip
2oo2	Low	Under Range	Yes	Yes	1oo1	Process Trip
2oo2	High	Over Range	Yes	Yes	1oo1	Process Trip
2oo3	Low	Under Range	Yes	Yes	1oo2	Process Trip
2oo3	High	Over Range	Yes	Yes	1oo2	Process Trip

Table 2			PLC software			
Logic	Process Trip	Transmitter setting	Out of range diagnostic	Channel Trip	Architecture degradation	
					1st failure	2nd failure
1oo1	Low	Under Range	Yes	Yes	Process Trip	--
1oo1	High	Over Range	Yes	Yes	Process Trip	--
1oo2	Low	Under Range	Yes	Yes	Process Trip	--
1oo2	High	Over Range	Yes	Yes	Process Trip	--
2oo2	Low	Under Range	Yes	Yes	1oo1	Process Trip
2oo2	High	Over Range	Yes	Yes	1oo1	Process Trip
2oo3	Low	Under Range	Yes	Yes	1oo2	Process Trip
2oo3	High	Over Range	Yes	Yes	1oo2	Process Trip

SIFs with unique voting schemes not defined by 1oo1, 1oo2, 2oo2, or 2oo3 are to be considered on a case-by-case basis.

[illegible]

Notes:

 SIL, RRF, MTTFS are achieved
  SIL & RRF targets are not achieved
  MTTFS target is not achieved

1

No.	SIF Tag / Description	TARGET		ACHIEVED			SIL achieved				Main Parameters									
		SIL	RRF	SIL	RRF	PFDavg/PFH	SIF		Arch. C.			Sensors			Final Elements					
		SIL-1	20	SIL-1	56	1,79E-02	Pr	AC	SC	Route		SE1	SE2	SE3	FE1	FE2	FE3	FE4	FE5	
1	M4-LT-1111-01	MTTFS	10	MTTFS	67		1	1	2	1H	Voting	1001			1001					
	On High High Level (LT-1) [1001] in Tank 100-1111 close valve XV-1 [1001]										Cpt	95%			73%					
											TI(y)	1,0			1,0					
											Beta									
											SFF	87%			52%					
											DC	83%			0%					
2	M4-LT-1112-01	MTTFS	10	MTTFS	45		2	1	2	1H	Voting	1001			1002					
	On High High Level (LT-1) [1001] in Tank 100-1111 close valve XV-1A/B [1002]										Cpt	95%			73%					
											TI(y)	1,0			1,0					
											Beta				10%					
											SFF	87%			52%					
											DC	83%			0%					
3	M4-LT-1212-01	MTTFS	10	MTTFS	43		2	2	2	1H	Voting	1002			1002					
	On High High Level (LT-1A/B) [1002] in Tank 100-1111 close valve XV-1A/B [1002]										Cpt	95%			73%					
											TI(y)	1,0			1,0					
											Beta	5%			10%					
											SFF	87%			52%					
											DC	83%			0%					
6	M4-PT-2312-06	MTTFS	10	MTTFS	47		2	2	3	1H	Voting	2003			1002					
	On High High Pressure (PT-6A/B/C) [2003] in Vessel 100-2312 close valves XV-6A/B [1002]										Cpt	94%			73%					
											TI(y)	1,0			1,0					
											Beta	5%			10%					
											SFF	81%			52%					
											DC	0%			0%					

Pr: Probability of failure

AC: Architectural Constraints

SC: Systematic Capability

SFF: Safe Failure Fraction

DC: Diagnostic Coverage=DD/(DD+DU)

RRF: Risk Reduction Factor

MTTFS in years: Mean Time To Fail Spuriously

 SIL, RRF, MTTFS are achieved

 SIL & RRF targets are not achieved

 MTTFS target is not achieved

EXTENDED SUMMARY OF SIL VERIFICATION

Site:

Doc:

Logo 2

No.	SIF Tag / Description	TARGET		ACHIEVED			SIL achieved				Main Parameters										
		SIL	RRF	SIL	RRF	PFDavg/PFH	SIF		Arch. C.			Sensors			Final Elements						
		SIL-2	200	SIL-2	458	2,18E-03		Pr	AC	SC	Route		SE1	SE2	SE3	FE1	FE2	FE3	FE4	FE5	
7	M4-PT-2312-06B	MTTFS	10	MTTFS	47			2	2	3	1H	Voting	2oo3			1oo2					
	On High High Pressure (PT-6A/B/C) [2oo3] in Vessel 100-2312 close valves XV-6A/B [1oo2].							Per subsystem				Cpt	94%			73%					
									SE LS FE				TI(y)	1,0			1,0				
									2 3 2				Beta	5%			10%				
													SFF	82%			52%				
													DC	0%			0%				
8	M4-PT-2312-06SS	MTTFS	10	MTTFS	47			Pr	AC	SC	Route		SE1	SE2	SE3	FE1	FE2	FE3	FE4	FE5	
	[Severe Service Case] On High High Pressure (PT-6A/B/C) [2oo3] in Vessel 100-2312 close valves XV-6A/B [1oo2]							2	2	3	1H	Voting	2oo3			1oo2					
									Per subsystem				Cpt	95%			63%				
									SE LS FE				TI(y)	1,0			1,0				
									2 3 2				Beta	5%			10%				
													SFF	76%			43%				
											DC	0%			0%						
10	M4-PS-1112-10	MTTFS	10	MTTFS	45			Pr	AC	SC	Route		SE1	SE2	SE3	FE1	FE2	FE3	FE4	FE5	
	On High High Pressure [1oo1] in Vessel close valves XV-6A/B [1oo2]							2	1	3	1H	Voting	1oo1			1oo2					
									Per subsystem				Cpt	90%			73%				
									SE LS FE				TI(y)	1,0			1,0				
									1 3 2				Beta				10%				
													SFF	39%			52%				
											DC	0%			0%						
11	M4-PT-1112-10	MTTFS	10	MTTFS	45			Pr	AC	SC	Route		SE1	SE2	SE3	FE1	FE2	FE3	FE4	FE5	
	On High High Pressure [1oo1] in Vessel close valves XV-6A/B [1oo2]							2	2	3	1H	Voting	1oo1			1oo2					
									Per subsystem				Cpt	90%			73%				
									SE LS FE				TI(y)	1,0			1,0				
									2 3 2				Beta				10%				
													SFF	90%			52%				
											DC	86%			0%						

Pr: Probability of failure
AC: Architectural Constraints
SC: Systematic Capability
SE: Sensor FE: Final Element

SFF: Safe Failure Fraction
DC: Diagnostic Coverage=DD/(DD+DU)
RRF: Risk Reduction Factor
MTTFS in years: Mean Time To Fail Spuriously

■ SIL, RRF, MTTFS are achieved ■ SIL & RRF targets are not achieved ■ MTTFS target is not achieved

No.	SIF Tag / Description	TARGET		ACHIEVED			SIL achieved				Main Parameters									
		SIL	RRF	SIL	RRF	PFDavg/PFH	SIF		Arch. C.			Sensors			Final Elements					
		SIL-2	200	SIL-2	469	2,13E-03	Pr	AC	SC	Route		SE1	SE2	SE3	FE1	FE2	FE3	FE4	FE5	
13	M4-PTTT-1212-13	MTTFS	10	MTTFS	29		2	2	3	1H	Voting	1oo1	1oo1		1oo2					
	On High Pressure PT-10 [OR] High Temperature TT-10 [1oo2] in Vessel close valves XV-6A/B [1oo2]										Cpt	90%	98%		73%					
											TI(y)	1,0	1,0		1,0					
											Beta				10%					
											SFF	90%	84%		52%					
											DC	86%	79%		0%					
16	M4-PT-1112-16	SIL-1	20	SIL-0	146	6,87E-03	Pr	AC	SC	Route		SE1	SE2	SE3	FE1	FE2	FE3	FE4	FE5	
	On High High Pressure (PT-1) [1oo1] in Vessel close valves XV-16A/B [1oo2]	MTTFS	10	MTTFS	46		2	0	2	1H	Voting	1oo1			1oo2					
											Cpt	90%			73%					
											TI(y)	1,0			1,0					
											Beta				10%					
											SFF	54%			52%					
17	M4-PT-1112-16-CMP	SIL-1	20	SIL-0	55	1,81E-02	Pr	AC	SC	Route		SE1	SE2	SE3	FE1	FE2	FE3	FE4	FE5	
	On High High Pressure (PT-1) [1oo1] in Vessel close valves XV-16A/B [1oo2] (90% credit by comparison used for PT-1 by comparing with PT-2 of BPCS)	MTTFS	10	MTTFS	45		1	0	2	1H	Voting	1oo1			1oo2					
											Cpt	54%			73%					
											TI(y)	1,0			1,0					
											Beta				10%					
											SFF	59%			52%					
19	M4-PT-1111-19	SIL-1	20	SIL-1	48	2,08E-02	Pr	AC	SC	Route		SE1	SE2	SE3	FE1	FE2	FE3	FE4	FE5	
	High High Pressure on PT closes feed valve. Calculation of Bypass impact	MTTFS	10	MTTFS	68		1	1	3	1H	Voting	1oo1			1oo1	--				
											Cpt	94%			73%					
											TI(y)	1,0			1,0					
											Beta	5%			10%					
											SFF	81%			52%					
										DC	74%			0%						

Pr: Probability of failure

AC: Architectural Constraints

SC: Systematic Capability

SE: Sensor FE: Final Element

SFF: Safe Failure Fraction

DC: Diagnostic Coverage=DD/(DD+DU)

RRF: Risk Reduction Factor

MTTFS in years: Mean Time To Fail Spuriously

 SIL, RRF, MTTFS are achieved

 SIL & RRF targets are not achieved

 MTTFS target is not achieved

	PROJECT NAME		Rev.1	20/08/2025	Logo 2
	EXTENDED SUMMARY OF SIL VERIFICATION		Site:		
			Doc:		

No.	SIF Tag / Description	TARGET		ACHIEVED			SIL achieved				Main Parameters												
		SIL	RRF	SIL	RRF	PFDavg/PFH	SIF		Arch. C.			Sensors			Final Elements								
		SIL-2	200	SIL-2	459	2,18E-03	Pr	AC	SC	Route		SE1	SE2	SE3	FE1	FE2	FE3	FE4	FE5				
20	SIF-20	MTTFS	10	MTTFS	47		2	2	3	1H	Voting	2oo3			1oo2	--							
	On High High Pressure (PT-6A/B/C) [2oo3] in Vessel 100-2312 close valves XV-6A/B [1oo2]. Calculation of Bypass impact																						
30	M5-FT-2312-30	MTTFS	10	MTTFS	27		2	2	3	1H	Voting	2oo3			1oo2	1oo2							
	On Low Low Air Combustion Flow (FT-30A/B/C) [2oo3] in Incinerator 100-2312 closes Fuel Gas Valves (1oo2 XV-30/31) & Natural Gas Valves (1oo2 XV-32/33) [2oo2 of FG & NG]																						
											Voting												
											Voting												

		Pr: Probability of failure AC: Architectural Constraints SC: Systematic Capability SE: Sensor FE: Final Element	SFF: Safe Failure Fraction DC: Diagnostic Coverage=DD/(DD+DU) RRF: Risk Reduction Factor MTTFS in years: Mean Time To Fail Spuriously

DETAILED SIL VERIFICATION				Rev.1	20/08/2025																																							
PROJECT NAME				Doc:																																								
SIF: M4-LT-1111-01 <table><tr><td colspan="2">Required</td><td>Achieved</td></tr><tr><td>SIL-1</td><td>SIL</td><td>SIL-1</td></tr><tr><td>20</td><td>RRF</td><td>56</td></tr><tr><td></td><td>PFDavg</td><td>1,79E-02</td></tr><tr><td>10</td><td>MTTFS (y)</td><td>67</td></tr></table><table><tr><td colspan="2">Achieved</td></tr><tr><td>PFDavg</td><td>SIL-1</td></tr><tr><td>Arch. C.</td><td>SIL-1</td></tr><tr><td>SC</td><td>SIL-2</td></tr></table> AC= Route 1H <table><tr><td></td><td>Achieved</td><td>PFDavg</td><td>MTTFS (years)</td></tr><tr><td>sensor</td><td>SIL-1</td><td>5,77E-04</td><td>836</td></tr><tr><td>logic solver</td><td>SIL-3</td><td>1,65E-04</td><td>178</td></tr><tr><td>actuator</td><td>SIL-1</td><td>1,72E-02</td><td>125</td></tr></table> On High High Level (LT-1) [1oo1] in Tank 100-1111 close valve XV-1 [1oo1] SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022. Out of range diagnostic: ON Sensor Fault: U.R. Channel Trip: No LT-1 1oo1 1oo2D ESD-1 Generic PLC SIL-3 1oo1 XV-1 PFDavg 3% 1% 96% MTTFS 8% 38% 54% Contribution sensor logic solver actuator HAZOP still open for this scenario. If IPL considered has not credit then SIL-2 is needed in this SIF. To achieve SIL-2: -Sensor: Route 2H or 1oo2. -Actuator: 1oo2 Devices used in this SIF: 3051 Pressure Transmitter (Coplanar Differential) Generic clean process connection IS Isolator AI/AI PLC: 1 AI. 1 DO Floating Ball Valve, C series, Full Stroke, Clean Service Actuator VL series, spring cylinder, Air-to-Retract Solenoid series 327, De-energize to trip DO interface, Solenoid Driver KFD0-SD-Ex 1						Required		Achieved	SIL-1	SIL	SIL-1	20	RRF	56		PFDavg	1,79E-02	10	MTTFS (y)	67	Achieved		PFDavg	SIL-1	Arch. C.	SIL-1	SC	SIL-2		Achieved	PFDavg	MTTFS (years)	sensor	SIL-1	5,77E-04	836	logic solver	SIL-3	1,65E-04	178	actuator	SIL-1	1,72E-02	125
Required		Achieved																																										
SIL-1	SIL	SIL-1																																										
20	RRF	56																																										
	PFDavg	1,79E-02																																										
10	MTTFS (y)	67																																										
Achieved																																												
PFDavg	SIL-1																																											
Arch. C.	SIL-1																																											
SC	SIL-2																																											
	Achieved	PFDavg	MTTFS (years)																																									
sensor	SIL-1	5,77E-04	836																																									
logic solver	SIL-3	1,65E-04	178																																									
actuator	SIL-1	1,72E-02	125																																									

DETAILED SIL VERIFICATION							Rev.1	20/08/2025
PROJECT NAME							Doc:	
SIF: M4-LT-1111-01								
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)	
sensor	LT-1	1oo1	5,77E-04	3	2	1	836	
sen_part	transmitter	--			3	--	--	
sen_part	process	--				--	--	
sen_part	interface	--			2	--	--	
logicsolver	ESD-1	1oo2D	1,65E-04	3	3	3	178	
actuator	XV-1	1oo1	1,72E-02	1	3	1	125	
act_part	valve	--			3	--	--	
act_part	actuator	--			3	--	--	
act_part	solenoid	--			3	--	--	
act_part	isolator	--			3	--	--	

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		95%	1,00	15		48	24	0	B	Route 1H
sen_part								0	B	
sen_part								0	A	
sen_part								0	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15		0	24	0	A	Route 1H
act_part								0	A	
act_part								0	A	
act_part								0	A	
act_part								0	A	

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	LT-1	1oo1	53	84	377	77	87%	
sen_part	transmitter	--	24	84	234	32		
sen_part	process	--	0	0	0	0		
sen_part	interface	--	29	0	143	45		
logicsolver	ESD-1	1oo2D	11617	129	3815	241	98%	
actuator	XV-1	1oo1	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION				Rev.1	20/08/2025																																							
PROJECT NAME				Doc:																																								
SIF: M4-LT-1112-01 <table><tr><th>Required</th><th colspan="2">Achieved</th></tr><tr><td>SIL-1</td><td>SIL</td><td>SIL-1</td></tr><tr><td>20</td><td>RRF</td><td>370</td></tr><tr><td></td><td>PFDavg</td><td>2,70E-03</td></tr><tr><td>10</td><td>MTTFS (y)</td><td>45</td></tr></table><table><tr><th colspan="2">Achieved</th></tr><tr><td>PFDavg</td><td>SIL-2</td></tr><tr><td>Arch. C.</td><td>SIL-1</td></tr><tr><td>SC</td><td>SIL-2</td></tr></table> AC= Route 1H <table><tr><th></th><th>Achieved</th><th>PFDavg</th><th>MTTFS (years)</th></tr><tr><td>sensor</td><td>SIL-1</td><td>5,77E-04</td><td>836</td></tr><tr><td>logic solver</td><td>SIL-3</td><td>1,67E-04</td><td>176</td></tr><tr><td>actuator</td><td>SIL-2</td><td>1,95E-03</td><td>66</td></tr></table>						Required	Achieved		SIL-1	SIL	SIL-1	20	RRF	370		PFDavg	2,70E-03	10	MTTFS (y)	45	Achieved		PFDavg	SIL-2	Arch. C.	SIL-1	SC	SIL-2		Achieved	PFDavg	MTTFS (years)	sensor	SIL-1	5,77E-04	836	logic solver	SIL-3	1,67E-04	176	actuator	SIL-2	1,95E-03	66
Required	Achieved																																											
SIL-1	SIL	SIL-1																																										
20	RRF	370																																										
	PFDavg	2,70E-03																																										
10	MTTFS (y)	45																																										
Achieved																																												
PFDavg	SIL-2																																											
Arch. C.	SIL-1																																											
SC	SIL-2																																											
	Achieved	PFDavg	MTTFS (years)																																									
sensor	SIL-1	5,77E-04	836																																									
logic solver	SIL-3	1,67E-04	176																																									
actuator	SIL-2	1,95E-03	66																																									
On High High Level (LT-1) [1oo1] in Tank 100-1111 close valve XV-1A/B [1oo2] Out of range diagnostic: ON Sensor Fault: U.R. Channel Trip: No LT-1 1oo1 1oo2D ESD-1 Generic PLC SIL-3 1oo2 XV-1A XV-1B				SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022. <table><tr><td>PFDavg</td><td>21%</td><td>6%</td><td>72%</td></tr><tr><td>MTTFS</td><td>5%</td><td>26%</td><td>69%</td></tr></table> Contribution ■ sensor ■ logic solver ■ actuator		PFDavg	21%	6%	72%	MTTFS	5%	26%	69%																															
PFDavg	21%	6%	72%																																									
MTTFS	5%	26%	69%																																									
HAZOP still open for this scenario. If IPL considered has not credit then SIL-2 is needed in this SIF. To achieve SIL-2: -Sensor: Route 2H or 1oo2.				Devices used in this SIF: 3051 Pressure Transmitter (Coplanar Differential) Generic clean process connection IS Isolator AI/AI PLC: 1 AI, 2 DO same module Floating Ball Valve, C series, Full Stroke, Clean Service Actuator VL series, spring cylinder, Air-to-Retract Solenoid series 327, De-energize to trip DO interface, Solenoid Driver KFD0-SD-Ex 1																																								

On High High Level (LT-1) [1oo1] in Tank 100-1111 close valve XV-1A/B [1oo2]

SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022.

Out of range diagnostic: ON

Sensor Fault: U.R.

Channel Trip: No

LT-1

1oo1

1oo2D

ESD-1

Generic PLC

SIL-3

1oo2

XV-1A

XV-1B

PFDavg

MTTFS

21%

6%

72%

5%

26%

69%

Contribution

sensor

logic solver

actuator

HAZOP still open for this scenario. If IPL considered has not credit then SIL-2 is needed in this SIF.

To achieve SIL-2:

-Sensor: Route 2H or 1oo2.

Devices used in this SIF:

3051 Pressure Transmitter (Coplanar Differential)

Generic clean process connection

IS Isolator AI/AI

PLC: 1 AI, 2 DO same module

Floating Ball Valve, C series, Full Stroke, Clean Service

Actuator VL series, spring cylinder, Air-to-Retract

Solenoid series 327, De-energize to trip

DO interface, Solenoid Driver KFD0-SD-Ex 1

12

DETAILED SIL VERIFICATION							Rev.1	20/08/2025
PROJECT NAME							Doc:	
SIF: M4-LT-1112-01								
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)	
sensor	LT-1	1oo1	5,77E-04	3	2	1	836	
sen_part	transmitter	--			3	--	--	
sen_part	process	--				--	--	
sen_part	interface	--			2	--	--	
logicsolver	ESD-1	1oo2D	1,67E-04	3	3	3	176	
actuator	XV-1	1oo2	1,95E-03	2	3	2	66	
act_part	valve	--			3	--	--	
act_part	actuator	--			3	--	--	
act_part	solenoid	--			3	--	--	
act_part	isolator	--			3	--	--	

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		95%	1,00	15		48	24	0	B	Route 1H
sen_part								0	B	
sen_part								0	A	
sen_part								0	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%	0	24	1	A	Route 1H
act_part								1	A	
act_part								1	A	
act_part								1	A	
act_part								1	A	

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	LT-1	1oo1	53	84	377	77	87%	
sen_part	transmitter	--	24	84	234	32		
sen_part	process	--	0	0	0	0		
sen_part	interface	--	29	0	143	45		
logicsolver	ESD-1	1oo2D	11756	130	3872	244	98%	
actuator	XV-1	1oo2	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION				Rev.1	20/08/2025																																							
PROJECT NAME				Doc:																																								
SIF: M4-LT-1212-01 <table><tr><td colspan="2">Required</td><td>Achieved</td></tr><tr><td>SIL-2</td><td>SIL</td><td>SIL-2</td></tr><tr><td>200</td><td>RRF</td><td>464</td></tr><tr><td></td><td>PFDavg</td><td>2,15E-03</td></tr><tr><td>10</td><td>MTTFS (y)</td><td>43</td></tr></table><table><tr><td colspan="2">Achieved</td></tr><tr><td>PFDavg</td><td>SIL-2</td></tr><tr><td>Arch. C.</td><td>SIL-2</td></tr><tr><td>SC</td><td>SIL-2</td></tr></table> AC= Route 1H <table><tr><td></td><td>Achieved</td><td>PFDavg</td><td>MTTFS (years)</td></tr><tr><td>sensor</td><td>SIL-2</td><td>2,91E-05</td><td>429</td></tr><tr><td>logic solver</td><td>SIL-3</td><td>1,70E-04</td><td>173</td></tr><tr><td>actuator</td><td>SIL-2</td><td>1,95E-03</td><td>66</td></tr></table>						Required		Achieved	SIL-2	SIL	SIL-2	200	RRF	464		PFDavg	2,15E-03	10	MTTFS (y)	43	Achieved		PFDavg	SIL-2	Arch. C.	SIL-2	SC	SIL-2		Achieved	PFDavg	MTTFS (years)	sensor	SIL-2	2,91E-05	429	logic solver	SIL-3	1,70E-04	173	actuator	SIL-2	1,95E-03	66
Required		Achieved																																										
SIL-2	SIL	SIL-2																																										
200	RRF	464																																										
	PFDavg	2,15E-03																																										
10	MTTFS (y)	43																																										
Achieved																																												
PFDavg	SIL-2																																											
Arch. C.	SIL-2																																											
SC	SIL-2																																											
	Achieved	PFDavg	MTTFS (years)																																									
sensor	SIL-2	2,91E-05	429																																									
logic solver	SIL-3	1,70E-04	173																																									
actuator	SIL-2	1,95E-03	66																																									
On High High Level (LT-1A/B) [1oo2] in Tank 100-1111 close valve XV-1A/B [1oo2] Out of range diagnostic: ON Sensor Fault: U.R. Channel Trip: No LT-1A LT-1B 1oo2 1oo2D ESD-1 Generic PLC SIL-3 1oo2 XV-1A XV-1B				SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022.																																								
PFDavg MTTFS 1% 8% 10% 25% 65% 91% Contribution ■ sensor ■ logic solver ■ actuator																																												
Devices used in this SIF: 3051 Pressure Transmitter (Coplanar Differential) Generic clean process connection IS Isolator AI/AI PLC: 2 AI, 2 DO same module Floating Ball Valve, C series, Full Stroke, Clean Service Actuator VL series, spring cylinder, Air-to-Retract Solenoid series 327, De-energize to trip DO interface, Solenoid Driver KFD0-SD-Ex 1																																												

On High High Level (LT-1A/B) [1oo2] in Tank 100-1111 close valve XV-1A/B [1oo2]

SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022.

Out of range diagnostic: ON

Sensor Fault: U.R.

Channel Trip: No

LT-1A

LT-1B

1oo2

1oo2D

ESD-1

Generic PLC
SIL-3

1oo2

XV-1A

XV-1B

PFDavg

MTTFS

1%

8%

10%

25%

91%

65%

Contribution

sensor

logic solver

actuator

Devices used in this SIF:

3051 Pressure Transmitter (Coplanar Differential)

Generic clean process connection

IS Isolator AI/AI

PLC: 2 AI, 2 DO same module

Floating Ball Valve, C series, Full Stroke, Clean Service

Actuator VL series, spring cylinder, Air-to-Retract

Solenoid series 327, De-energize to trip

DO interface, Solenoid Driver KFD0-SD-Ex 1

14

DETAILED SIL VERIFICATION						Rev.1	20/08/2025
PROJECT NAME						Doc:	
SIF: M4-LT-1212-01							
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)
sensor	LT-1	1oo2	2,91E-05	4	2	2	429
sen_part	transmitter	--			3	--	--
sen_part	process	--				--	--
sen_part	interface	--			2	--	--
logicsolver	ESD-1	1oo2D	1,70E-04	3	3	3	173
actuator	XV-1	1oo2	1,95E-03	2	3	2	66
act_part	valve	--			3	--	--
act_part	actuator	--			3	--	--
act_part	solenoid	--			3	--	--
act_part	isolator	--			3	--	--

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		95%	1,00	15	5%	48	24	1	B	Route 1H
sen_part								1	B	
sen_part								1	A	
sen_part								1	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%	48	24	1	A	Route 1H
act_part								1	A	
act_part								1	A	
act_part								1	A	
act_part								1	A	

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	LT-1	1oo2	53	84	377	77	87%	
sen_part	transmitter	--	24	84	234	32		
sen_part	process	--	0	0	0	0		
sen_part	interface	--	29	0	143	45		
logicsolver	ESD-1	1oo2D	11804	133	3920	247	98%	
actuator	XV-1	1oo2	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION

Rev.120/08/2025

PROJECT NAME

Doc:

SIF: M4-PT-2312-06

Required	Achieved
SIL-2	SIL
200	RRF
	PFDavg
10	MTTFS (y)

Achieved
PFDavg
Arch. C.
SC

Achieved
SIL-2
SIL-2
SIL-3

Achieved	PFDavg	MTTFS (years)
SIL-2	5,29E-05	3417
SIL-3	1,73E-04	171
SIL-2	1,95E-03	66

sensor

logic solver

actuator

AC= Route 1H

On High High Pressure (PT-6A/B/C) [2oo3] in Vessel 100-2312 close valves XV-6A/B [1oo2]

SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022.

Out of range diagnostic: ON

Sensor Fault: --

Channel Trip: Yes

PT-6A

PT-6B

PT-6C

2oo3

1oo2D

ESD-1

Generic PLC

SIL-3

1oo2

XV-6A

XV-6B

PFDavg

MTTFS

2%8%90%

1%27%71%

Contribution

■ sensor

■ logic solver

■ actuator

Devices used in this SIF:

3051 Pressure Transmitter (Coplanar Absolute)

1199 Remote Seal, High Trip, normal service

PLC: 3 AI, 2 DO same module

Floating Ball Valve, C series, Full Stroke, Clean Service

Actuator VL series, spring cylinder, Air-to-Retract

Solenoid series 327, De-energize to trip

DO interface, Solenoid Driver KFD0-SD-Ex 1

16

DETAILED SIL VERIFICATION							Rev.1	20/08/2025
PROJECT NAME							Doc:	
SIF: M4-PT-2312-06								
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)	
sensor	PT-6	2oo3	5,29E-05	4	3	2	3.417	
sen_part	transmitter	--			3	--	--	
sen_part	seal	--			3	--	--	
logicsolver	ESD-1	1oo2D	1,73E-04	3	3	3	171	
actuator	XV-6	1oo2	1,95E-03	2	3	2	66	
act_part	valve	--			3	--	--	
act_part	actuator	--			3	--	--	
act_part	solenoid	--			3	--	--	
act_part	isolator	--			3	--	--	

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		94%	1,00	15	5%	48	24	1	B	Route 1H
sen_part								1	B	
sen_part								1	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%	48	24	1	A	Route 1H
act_part								1	A	
act_part								1	A	
act_part								1	A	
act_part								1	A	

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	PT-6	2oo3	279	94	0	87	81%	
sen_part	transmitter	--	279	94	0	41		
sen_part	seal	--	0	0	0	46		
logicsolver	ESD-1	1oo2D	11852	136	3968	250	98%	
actuator	XV-6	1oo2	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION				Rev.1		20/08/2025																																									
PROJECT NAME				Doc:																																											
SIF: M4-PT-2312-06B <table><tr><td colspan="2">Required</td><td colspan="2">Achieved</td></tr><tr><td>SIL-2</td><td>SIL</td><td>SIL-2</td><td></td></tr><tr><td>200</td><td>RRF</td><td>458</td><td></td></tr><tr><td></td><td>PFDavg</td><td>2,18E-03</td><td></td></tr><tr><td>10</td><td>MTTFS (y)</td><td>47</td><td></td></tr></table> AC= Route 1H <table><tr><td colspan="2">Achieved</td></tr><tr><td>PFDavg</td><td>SIL-2</td></tr><tr><td>Arch. C.</td><td>SIL-2</td></tr><tr><td>SC</td><td>SIL-3</td></tr></table> sensor logic solver actuator <table><tr><td>Achieved</td><td>PFDavg</td><td>MTTFS (years)</td></tr><tr><td>SIL-2</td><td>5,37E-05</td><td>3144</td></tr><tr><td>SIL-3</td><td>1,73E-04</td><td>171</td></tr><tr><td>SIL-2</td><td>1,95E-03</td><td>66</td></tr></table> On High High Pressure (PT-6A/B/C) [2oo3] in Vessel 100-2312 close valves XV-6A/B [1oo2]. SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022. Out of range diagnostic: ON Sensor Fault: -- Channel Trip: Yes PT-6A PT-6B PT-6C 2oo3 1oo2D ESD-1 Generic PLC SIL-3 1oo2 XV-6A XV-6B PFDavg MTTFS 2% 8% 1% 27% 71% Contribution ■ sensor ■ logic solver ■ actuator Devices used in this SIF: PT700 Pressure Transmitter 1199 Remote Seal, High Trip, normal service PLC: 3 AI, 2 DO same module Floating Ball Valve, C series, Full Stroke, Clean Service Actuator VL series, spring cylinder, Air-to-Retract Solenoid series 327, De-energize to trip DO interface, Solenoid Driver KFD0-SD-Ex 1								Required		Achieved		SIL-2	SIL	SIL-2		200	RRF	458			PFDavg	2,18E-03		10	MTTFS (y)	47		Achieved		PFDavg	SIL-2	Arch. C.	SIL-2	SC	SIL-3	Achieved	PFDavg	MTTFS (years)	SIL-2	5,37E-05	3144	SIL-3	1,73E-04	171	SIL-2	1,95E-03	66
Required		Achieved																																													
SIL-2	SIL	SIL-2																																													
200	RRF	458																																													
	PFDavg	2,18E-03																																													
10	MTTFS (y)	47																																													
Achieved																																															
PFDavg	SIL-2																																														
Arch. C.	SIL-2																																														
SC	SIL-3																																														
Achieved	PFDavg	MTTFS (years)																																													
SIL-2	5,37E-05	3144																																													
SIL-3	1,73E-04	171																																													
SIL-2	1,95E-03	66																																													

DETAILED SIL VERIFICATION						Rev.1	20/08/2025
PROJECT NAME						Doc:	
SIF: M4-PT-2312-06B							
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)
sensor	PT-6	2oo3	5,37E-05	4	3	2	3.144
sen_part	transmitter	--			3	--	--
sen_part	seal	--			3	--	--
logicsolver	ESD-1	1oo2D	1,73E-04	3	3	3	171
actuator	XV-6	1oo2	1,95E-03	2	3	2	66
act_part	valve	--			3	--	--
act_part	actuator	--			3	--	--
act_part	solenoid	--			3	--	--
act_part	isolator	--			3	--	--

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		94%	1,00	15	5%	48	24	1	B	Route 1H
sen_part								1	B	
sen_part								1	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%	48	24	1	A	Route 1H
act_part								1	A	
act_part								1	A	
act_part								1	A	
act_part								1	A	

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	PT-6	2oo3	364	40	0	88	82%	
sen_part	transmitter	--	364	40	0	42		
sen_part	seal	--	0	0	0	46		
logicsolver	ESD-1	1oo2D	11852	136	3968	250	98%	
actuator	XV-6	1oo2	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION					Rev.120/08/2025	
PROJECT NAME					Doc:	
SIF: M4-PT-2312-06SS						
Required		Achieved	Achieved			
SIL-2	SIL	SIL-2	PFDavg	SIL-2		
200	RRF	231	Arch. C.	SIL-2		
	PFDavg	4,32E-03	SC	SIL-3		
10	MTTFS (y)	47	AC= Route 1H			
[Severe Service Case] On High High Pressure (PT-6A/B/C) [2oo3] in Vessel 100-2312 close valves XV-6A/B [1oo2]					SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022.	
Out of range diagnostic: ON Sensor Fault: -- Channel Trip: Yes						
PT-6A PT-6B PT-6C 2oo3 1oo2D ESD-1 Generic PLC SIL-3 1oo2 XV-6A XV-6B						
PFDavg 2% 4% 94% MTTFS 1% 27% 71% Contribution sensor logic solver actuator						
Devices used in this SIF:						
3051 Pressure Transmitter (Coplanar Absolute)						
1199 Remote Seal, High Trip, severe service						
PLC: 3 AI, 2 DO same module						
Floating Ball Valve, C series, Full Stroke, Severe Service						
Actuator VL series, spring cylinder, Air-to-Retract						
Solenoid series 327, De-energize to trip						
DO interface, Solenoid Driver KFD0-SD-Ex 1						

DETAILED SIL VERIFICATION						Rev.1	20/08/2025
PROJECT NAME						Doc:	
SIF: M4-PT-2312-06SS							
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)
sensor	PT-6	2oo3	6,62E-05	4	3	2	3.406
sen_part	transmitter	--			3	--	--
sen_part	seal	--			3	--	--
logicsolver	ESD-1	1oo2D	1,73E-04	3	3	3	171
actuator	XV-6	1oo2	4,09E-03	2	3	2	66
act_part	valve	--			3	--	--
act_part	actuator	--			3	--	--
act_part	solenoid	--			3	--	--
act_part	isolator	--			3	--	--

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		95%	1,00	15	5%	48	24	1	B	Route 1H
sen_part								1	B	
sen_part								1	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		63%	1,00	15	10%	48	24	1	A	Route 1H
act_part								1	A	
act_part								1	A	
act_part								1	A	
act_part								1	A	

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	PT-6	2oo3	279	94	0	117	76%	
sen_part	transmitter	--	279	94	0	41		
sen_part	seal	--	0	0	0	76		
logicsolver	ESD-1	1oo2D	11852	136	3968	250	98%	
actuator	XV-6	1oo2	0	916	0	1196	43%	
act_part	valve	--	0	0	0	809		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION

Rev.120/08/2025

PROJECT NAME

Doc:

SIF: M4-PS-1112-10

Required	Achieved
SIL-2	SIL
200	RRF
	PFDavg
10	MTTFS (y)

Achieved
PFDavg
Arch. C.
SC

Achieved
SIL-2
SIL-1
SIL-3

Achieved	PFDavg	MTTFS (years)
SIL-1	2,13E-03	892
SIL-3	1,07E-04	166
SIL-2	1,95E-03	66

SIL-1	238
4,20E-03	45

AC= Route 1H

On High High Pressure [1oo1] in Vessel close valves XV-6A/B [1oo2]

SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022.

PSHH-6

1oo1

1oo2D

ESD-1

Generic PLC
SIL-3

1oo2

XV-6A
XV-6B

This SIF doesn't meet AC requirement in the sensor.

Recommendation: replace switch by transmitter.

PFDavg

MTTFS

51%

3%

47%

5%

27%

68%

Contribution

sensor

logic solver

actuator

Devices used in this SIF:

Absolute Pressure Switch series M, B, A, D, PC, PX

Generic clean process connection

PLC: 1 DI, 2 DO same module

Floating Ball Valve, C series, Full Stroke, Clean Service

Actuator VL series, spring cylinder, Air-to-Retract

Solenoid series 327, De-energize to trip

DO interface, Solenoid Driver KFD0-SD-Ex 1

22

DETAILED SIL VERIFICATION							Rev.1	20/08/2025
PROJECT NAME							Doc:	
SIF: M4-PS-1112-10								
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)	
sensor	PSHH-6	1oo1	2,13E-03	2	3	1	892	
sen_part	switch	--			3	--	--	
sen_part	process	--				--	--	
logicsolver	ESD-1	1oo2D	1,07E-04	3	3	3	166	
actuator	XV-6	1oo2	1,95E-03	2	3	2	66	
act_part	valve	--			3	--	--	
act_part	actuator	--			3	--	--	
act_part	solenoid	--			3	--	--	
act_part	isolator	--			3	--	--	

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		90%	1,00	15			24	0	A	Route 1H
sen_part								0	A	
sen_part								0	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%		24	1	A	Route 1H
act_part								1	A	
act_part								1	A	
act_part								1	A	
act_part								1	A	

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	PSHH-6	1oo1	0	128	0	203	39%	
sen_part	switch	--	0	128	0	203		
sen_part	process	--	0	0	0	0		
logicsolver	ESD-1	1oo2D	11412	154	3371	165	99%	
actuator	XV-6	1oo2	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION				Rev.1		20/08/2025																																													
PROJECT NAME				Doc:																																															
SIF: M4-PT-1112-10 <table><tr><td colspan="2">Required</td><td colspan="2">Achieved</td></tr><tr><td>SIL-2</td><td>SIL</td><td>SIL-2</td><td></td></tr><tr><td>200</td><td>RRF</td><td>392</td><td></td></tr><tr><td></td><td>PFDavg</td><td>2,55E-03</td><td></td></tr><tr><td>10</td><td>MTTFS (y)</td><td>45</td><td></td></tr></table><table><tr><td colspan="2">Achieved</td></tr><tr><td>PFDavg</td><td>SIL-2</td></tr><tr><td>Arch. C.</td><td>SIL-2</td></tr><tr><td>SC</td><td>SIL-3</td></tr></table> AC= Route 1H <table><tr><td></td><td>Achieved</td><td>PFDavg</td><td>MTTFS (years)</td></tr><tr><td>sensor</td><td>SIL-2</td><td>4,31E-04</td><td>928</td></tr><tr><td>logic solver</td><td>SIL-3</td><td>1,67E-04</td><td>176</td></tr><tr><td>actuator</td><td>SIL-2</td><td>1,95E-03</td><td>66</td></tr></table> On High High Pressure [1oo1] in Vessel close valves XV-6A/B [1oo2] SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022. Out of range diagnostic: ON Sensor Fault: U.R. Channel Trip: No PT-6 1oo1 1oo2D 1oo2 XV-6A XV-6B ESD-1 Generic PLC SIL-3 PFDavg MTTFS 17% 7% 77% 5% 26% 69% Contribution sensor logic solver actuator Devices used in this SIF: 3051 Pressure Transmitter (Coplanar Absolute) Generic clean process connection PLC: 1 AI, 2 DO same module Floating Ball Valve, C series, Full Stroke, Clean Service Actuator VL series, spring cylinder, Air-to-Retract Solenoid series 327, De-energize to trip DO interface, Solenoid Driver KFD0-SD-Ex 1								Required		Achieved		SIL-2	SIL	SIL-2		200	RRF	392			PFDavg	2,55E-03		10	MTTFS (y)	45		Achieved		PFDavg	SIL-2	Arch. C.	SIL-2	SC	SIL-3		Achieved	PFDavg	MTTFS (years)	sensor	SIL-2	4,31E-04	928	logic solver	SIL-3	1,67E-04	176	actuator	SIL-2	1,95E-03	66
Required		Achieved																																																	
SIL-2	SIL	SIL-2																																																	
200	RRF	392																																																	
	PFDavg	2,55E-03																																																	
10	MTTFS (y)	45																																																	
Achieved																																																			
PFDavg	SIL-2																																																		
Arch. C.	SIL-2																																																		
SC	SIL-3																																																		
	Achieved	PFDavg	MTTFS (years)																																																
sensor	SIL-2	4,31E-04	928																																																
logic solver	SIL-3	1,67E-04	176																																																
actuator	SIL-2	1,95E-03	66																																																

DETAILED SIL VERIFICATION							Rev.1	20/08/2025
PROJECT NAME							Doc:	
SIF: M4-PT-1112-10								
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)	
sensor	PT-6	1oo1	4,31E-04	3	3	2	928	
sen_part	transmitter	--			3	--	--	
sen_part	process	--				--	--	
logicsolver	ESD-1	1oo2D	1,67E-04	3	3	3	176	
actuator	XV-6	1oo2	1,95E-03	2	3	2	66	
act_part	valve	--			3	--	--	
act_part	actuator	--			3	--	--	
act_part	solenoid	--			3	--	--	
act_part	isolator	--			3	--	--	

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		90%	1,00	15			24	0	B	Route 1H
sen_part								0	B	
sen_part								0	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%		24	1	A	Route 1H
act_part								1	A	
act_part								1	A	
act_part								1	A	
act_part								1	A	

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	PT-6	1oo1	29	94	250	41	90%	
sen_part	transmitter	--	29	94	250	41		
sen_part	process	--	0	0	0	0		
logicsolver	ESD-1	1oo2D	11756	130	3872	244	98%	
actuator	XV-6	1oo2	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION

Rev.120/08/2025

PROJECT NAME

Doc:

SIF: M4-PTTT-1212-13

Required	Achieved
SIL-2	SIL
200	RRF
	PFDavg
10	MTTFS (y)

Achieved
PFDavg
Arch. C.
SC

Achieved
SIL-2
SIL-2
SIL-3

Achieved	PFDavg	MTTFS (years)
SIL-3	5,63E-06	138
SIL-3	1,70E-04	173
SIL-2	1,95E-03	66

On High Pressure PT-10 [OR] High Temperature TT-10 [1oo2] in Vessel close valves XV-6A/B [1oo2]

SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022.

Out of range diagnostic: ONSensor Fault: U.R.Channel Trip: No

PT-10

TT-10

1oo1

1oo1

1oo2

1oo2

1oo2D

ESD-1

Generic PLC
SIL-3

1oo2

XV-6A
XV-6B

PFDavg

MTTFS

0%
8%
92%

26%
20%
54%

Contribution

■ sensor
■ logic solver
■ actuator

Devices used in this SIF:

3051 Pressure Transmitter (Coplanar Absolute)

YTA710 Temperature Transmitter

Generic RTD 2/3 wires

PLC: 2 AI, 2 DO same module

Floating Ball Valve, C series, Full Stroke, Clean Service

Actuator VL series, spring cylinder, Air-to-Retract

Solenoid series 327, De-energize to trip

DO interface, Solenoid Driver KFD0-SD-Ex 1

26

DETAILED SIL VERIFICATION						Rev.1	20/08/2025
PROJECT NAME						Doc:	
SIF: M4-PTTT-1212-13							
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)
SEN_VOTING		1oo2	5,63E-06	4	3	2	138
sensor	PT-10	1oo1			3	--	--
sen_part	transmitter	--			3	--	--
sensor	TT-10	1oo1			3	--	--
sen_part	transmitter	--			3	--	173
sen_part	process	--			3	--	--
logicsolver	ESD-1	1oo2D	1,70E-04	3	3	3	173
actuator	XV-6	1oo2	1,95E-03	2	3	2	66
act_part	valve	--			3	--	--
act_part	actuator	--			3	--	--
act_part	solenoid	--			3	--	--
act_part	isolator	--			3	--	--

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
SEN_VOTING					1%			1	B	Route 1H
sensor		90%	1,00	15		48	24	0	B	
sen_part								0	B	
sensor		98%	1,00	15		48	24	0	B	
sen_part								0	B	
sen_part								0	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%		24	1	A	Route 1H
act_part								1	A	
act_part								1	A	
act_part								1	A	
act_part								1	A	

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
SEN_VOTING		1oo2	347	64	971	245	85%	
sensor	PT-10	1oo1	29	94	250	41		
sen_part	transmitter	--	29	94	250	41		
sensor	TT-10	1oo1	665	34	1691	448		
sen_part	transmitter	--	65	34	691	48		
sen_part	process	--	600	0	1000	400		
logicsolver	ESD-1	1oo2D	11804	133	3920	247	98%	
actuator	XV-6	1oo2	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION				Rev.1 20/08/2025	
PROJECT NAME				Doc:	
SIF: M4-PT-1112-16					
Required		Achieved	Achieved		
SIL-1	SIL	SIL-0	PFDavg	SIL-2	sensor logic solver actuator
20	RRF	146	Arch. C.	SIL-0	
	PFDavg	6,87E-03	SC	SIL-2	
10	MTTFS (y)	46			
			AC= Route 1H		
On High High Pressure (PT-1) [1oo1] in Vessel close valves XV-16A/B [1oo2]				SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022.	
Out of range diagnostic: ON Sensor Fault: U.R. Channel Trip: No					
PT-1	1oo1	1oo2D	1oo2 XV-16A XV-16B		
ESD-1					
Generic PLC SIL-3					
This SIF doesn't meet AC requirement in the sensor. We have used failure rates of generic PT which conservative. Recommendation: use a certificated transmitter with better failure rate values.					
PFDavg MTTFS 69% 2% 28% 5% 26% 70% Contribution ■ sensor ■ logic solver ■ actuator					
Devices used in this SIF:					
Generic Pressure Transmitter					
Generic clean process connection					
PLC: 1 AI, 2 DO same module					
Floating Ball Valve, C series, Full Stroke, Clean Service					
Actuator VL series, spring cylinder, Air-to-Retract					
Solenoid series 327, De-energize to trip					
DO interface, Solenoid Driver KFD0-SD-Ex 1					

DETAILED SIL VERIFICATION							Rev.1	20/08/2025
PROJECT NAME							Doc:	
SIF: M4-PT-1112-16								
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)	
sensor	PT-1	1oo1	4,75E-03	2	2	0	993	
sen_part	transmitter	--			2	--	--	
sen_part	process connection	--				--	--	
logicsolver	ESD-1	1oo2D	1,67E-04	3	3	3	176	
actuator	XV-16	1oo2	1,95E-03	2	3	2	66	
act_part	valve	--			3	--	--	
act_part	actuator	--			3	--	--	
act_part	solenoid	--			3	--	--	
act_part	isolator	--			3	--	--	

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		90%	1,00	15		48	24	0	B	Route 1H
sen_part								0	B	
sen_part								0	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%	48	24	1	A	Route 1H
act_part								1	A	
act_part								1	A	
act_part								1	A	
act_part								1	A	

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	PT-1	1oo1	115	0	415	450	54%	
sen_part	transmitter	--	115	0	415	450		
sen_part	process connection	--	0	0	0	0		
logicsolver	ESD-1	1oo2D	11756	130	3872	244	98%	
actuator	XV-16	1oo2	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION

Rev.120/08/2025

PROJECT NAME

Doc:

SIF: M4-PT-1112-16-CMP

Required	Achieved
SIL-1	SIL SIL-0
20	RRF 55
	PFDavg 1,81E-02
10	MTTFS (y) 45

Achieved
PFDavg SIL-1
Arch. C. SIL-0
SC SIL-2

AC= Route 1H

Achieved	PFDavg	MTTFS (years)
sensor SIL-0	1,60E-02	796
logic solver SIL-3	1,70E-04	173
actuator SIL-2	1,95E-03	66

On High High Pressure (PT-1) [1oo1] in Vessel close valves XV-16A/B [1oo2] (90% credit by comparison used for PT-1 by comparing with PT-2 of BPCS)

SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022.

Out of range diagnostic: ON

Sensor Fault: U.R.

Channel Trip: No

PT-1

1oo1

1oo2D

1oo2

XV-16A

XV-16B

ESD-1

Generic PLC

SIL-3

PFDavg

MTTFS

88%

1%

11%

6%

26%

68%

Contribution

sensor

logic solver

actuator

Devices used in this SIF:

Generic PT with credit by comparison

Generic clean process connection

IS Isolator AI/AI

PLC: 2 AI, 2 DO same module

Floating Ball Valve, C series, Full Stroke, Clean Service

Actuator VL series, spring cylinder, Air-to-Retract

Solenoid series 327, De-energize to trip

DO interface, Solenoid Driver KFD0-SD-Ex 1

DETAILED SIL VERIFICATION						Rev.1	20/08/2025
PROJECT NAME						Doc:	
SIF: M4-PT-1112-16-CMP							
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)
sensor	PT-1	1oo1	1,60E-02	1	2	0	796
sen_part	transmitter	--			2	--	--
sen_part	process connection	--				--	--
sen_part	splitter	--			2	--	--
logicsolver	ESD-1	1oo2D	1,70E-04	3	3	3	173
actuator	XV-16	1oo2	1,95E-03	2	3	2	66
act_part	valve	--			3	--	--
act_part	actuator	--			3	--	--
act_part	solenoid	--			3	--	--
act_part	isolator	--			3	--	--

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		54%	1,00	15		48	24	0	B	Route 1H
sen_part								0	B	
sen_part								0	A	
sen_part								0	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%	48	24	1	A	Route 1H
act_part								1	A	
act_part								1	A	
act_part								1	A	
act_part								1	A	

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	PT-1	1oo1	144	0	558	495	59%	
sen_part	transmitter	--	115	0	415	450		
sen_part	process connection	--	0	0	0	0		
sen_part	splitter	--	29	0	143	45		
logicsolver	ESD-1	1oo2D	11804	133	3920	247	98%	
actuator	XV-16	1oo2	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION

Rev.120/08/2025

PROJECT NAME

Doc:

SIF: M4-PT-1111-19

Required	Achieved
SIL-1	SIL
20	RRF
	PFDavg
10	MTTFS (y)

Achieved
PFDavg
Arch. C.
SC

Achieved
SIL-1
SIL-1
SIL-3

Achieved	PFDavg	MTTFS (years)
SIL-1	7,01E-04	928
SIL-3	1,65E-04	178
SIL-1	1,99E-02	125

High High Pressure on PT closes feed valve. Calculation of Bypass impact

SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022.

Out of range diagnostic: ON

Sensor Fault: U.R.

Channel Trip: No

PT-6

1001

1002D

ESD-1

Generic PLC

SIL-3

1001

XV-6

PFDavg

MTTFS

3%1%96%

7%38%55%

Contribution

sensor

logic solver

actuator

Devices used in this SIF:

3051 Pressure Transmitter (Coplanar Absolute)

1199 Remote Seal, High Trip, normal service

PLC: 1 AI. 1 DO

Floating Ball Valve, C series, Full Stroke, Clean Service

Actuator VL series, spring cylinder, Air-to-Retract

Solenoid series 327, De-energize to trip

DO interface, Solenoid Driver KFD0-SD-Ex 1

32

DETAILED SIL VERIFICATION							Rev.1	20/08/2025
PROJECT NAME							Doc:	
SIF: M4-PT-1111-19								
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)	
sensor	PT-6	1oo1	7,01E-04	3	3	1	928	
sen_part	transmitter	--			3	--	--	
sen_part	seal	--			3	--	--	
logicsolver	ESD-1	1oo2D	1,65E-04	3	3	3	178	
actuator	XV-6	1oo1	1,72E-02	1	3	1	125	
act_part	valve	--			3	--	--	
act_part	actuator	--			3	--	--	
act_part	solenoid	--			3	--	--	
act_part	isolator	--			3	--	--	
actuator	BYPASS	--	2,74E-03	2		--	--	

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		94%	1,00	15	5%	48	24	0	B	Route 1H
sen_part								0	B	
sen_part								0	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%	48	24	0	A	Route 1H
act_part								0	A	
act_part								0	A	
act_part								0	A	
act_part								0	A	
actuator								--		

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	PT-6	1oo1	29	94	250	87	81%	
sen_part	transmitter	--	29	94	250	41		
sen_part	seal	--	0	0	0	46		
logicsolver	ESD-1	1oo2D	11617	129	3815	241	98%	
actuator	XV-6	1oo1	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		
actuator	BYPASS	--						

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION				Rev.1	20/08/2025																																		
PROJECT NAME				Doc:																																			
SIF: SIF-20 Required <table><tr><td>SIL-2</td><td>SIL</td><td>SIL-2</td></tr><tr><td>200</td><td>RRF</td><td>459</td></tr><tr><td></td><td>PFDavg</td><td>2,18E-03</td></tr><tr><td>10</td><td>MTTFS (y)</td><td>47</td></tr></table> Achieved <table><tr><td>PFDavg</td><td>SIL-2</td></tr><tr><td>Arch. C.</td><td>SIL-2</td></tr><tr><td>SC</td><td>SIL-3</td></tr></table> AC= Route 1H <table><tr><td></td><td>Achieved</td><td>PFDavg</td><td>MTTFS (years)</td></tr><tr><td>sensor</td><td>SIL-2</td><td>5,29E-05</td><td>3433</td></tr><tr><td>logic solver</td><td>SIL-3</td><td>1,73E-04</td><td>171</td></tr><tr><td>actuator</td><td>SIL-2</td><td>1,95E-03</td><td>66</td></tr></table> On High High Pressure (PT-6A/B/C) [2oo3] in Vessel 100-2312 close valves XV-6A/B [1oo2]. Calculation of Bypass impact SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022. Out of range diagnostic: ON Sensor Fault: -- Channel Trip: Yes PT-6A PT-6B PT-6C 2oo3 1oo2D ESD-1 Generic PLC SIL-3 1oo2 XV-6A XV-6B PFDavg 2% 8% 90% MTTFS 1% 27% 71% Contribution ■ sensor ■ logic solver ■ actuator Devices used in this SIF: 3051 Pressure Transmitter (Coplanar Absolute) 1199 Remote Seal, High Trip, normal service PLC: 3 AI, 2 DO same module Floating Ball Valve, C series, Full Stroke, Clean Service Actuator VL series, spring cylinder, Air-to-Retract Solenoid series 327, De-energize to trip DO interface, Solenoid Driver KFD0-SD-Ex 1						SIL-2	SIL	SIL-2	200	RRF	459		PFDavg	2,18E-03	10	MTTFS (y)	47	PFDavg	SIL-2	Arch. C.	SIL-2	SC	SIL-3		Achieved	PFDavg	MTTFS (years)	sensor	SIL-2	5,29E-05	3433	logic solver	SIL-3	1,73E-04	171	actuator	SIL-2	1,95E-03	66
SIL-2	SIL	SIL-2																																					
200	RRF	459																																					
	PFDavg	2,18E-03																																					
10	MTTFS (y)	47																																					
PFDavg	SIL-2																																						
Arch. C.	SIL-2																																						
SC	SIL-3																																						
	Achieved	PFDavg	MTTFS (years)																																				
sensor	SIL-2	5,29E-05	3433																																				
logic solver	SIL-3	1,73E-04	171																																				
actuator	SIL-2	1,95E-03	66																																				

DETAILED SIL VERIFICATION							Rev.1	20/08/2025
PROJECT NAME							Doc:	
SIF: SIF-20								
Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)	
sensor	PT-6	2oo3	5,29E-05	4	3	2	3.433	
sen_part	transmitter	--			3	--	--	
sen_part	seal	--			3	--	--	
logicsolver	ESD-1	1oo2D	1,73E-04	3	3	3	171	
actuator	XV-6	1oo2	1,95E-03	2	3	2	66	
act_part	valve	--			3	--	--	
act_part	actuator	--			3	--	--	
act_part	solenoid	--			3	--	--	
act_part	isolator	--			3	--	--	
actuator	BYPASS	--				--	--	

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		94%	1,00	15	5%	48	24	1	B	Route 1H
sen_part								1	B	
sen_part								1	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%	48	24	1	A	Route 1H
act_part								1	A	
act_part								1	A	
act_part								1	A	
act_part								1	A	
actuator								--		

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	PT-6	2oo3	279	94	0	87	81%	
sen_part	transmitter	--	279	94	0	41		
sen_part	seal	--	0	0	0	46		
logicsolver	ESD-1	1oo2D	11852	136	3968	250	98%	
actuator	XV-6	1oo2	0	916	0	829	52%	
act_part	valve	--	0	0	0	442		
act_part	actuator	--	0	286	0	199		
act_part	solenoid	--	0	516	0	188		
act_part	isolator	--	0	114	0	0		
actuator	BYPASS	--						

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION

Rev.120/08/2025

PROJECT NAME

Doc:

SIF: M5-FT-2312-30

Required		Achieved
SIL-2	SIL	SIL-2
200	RRF	243
	PFDavg	4,11E-03
10	MTTFS (y)	27

	Achieved
PFDavg	SIL-2
Arch. C.	SIL-2
SC	SIL-3

AC= Route 1H

	Achieved	PFDavg	MTTFS (years)
sensor	SIL-3	2,55E-05	3714
logic solver	SIL-3	1,78E-04	167
actuator	SIL-2	3,91E-03	33

On Low Low Air Combustion Flow (FT-30A/B/C) [2oo3] in Incinerator 100-2312 closes Fuel Gas Valves (1oo2 XV-30/31) & Natural Gas Valves (1oo2 XV-32/33) [2oo2 of FG & NG]

SIL Verification according to IEC61508/61511 & ISA TR84.00.02:2022.

Out of range diagnostic: ONSensor Fault: --Channel Trip: Yes

FT-30A

FT-30B

FT-30C

2oo3

1oo2D2oo21oo21oo2

ESD-1Generic PLCSIL-3

[FG] XV-30[FG] XV-31[NG] XV-32[NG] XV-33

PFDavg

MTTFS

1%4%95%1%16%83%

Contribution

sensor

logic solver

actuator

Devices used in this SIF:

3051 Pressure Transmitter (Coplanar Differential)

Generic clean process connection

PLC: 3 AI, 4 DO same module

36

DETAILED SIL VERIFICATION

Rev.1

20/08/2025

PROJECT NAME

Doc:

SIF: M5-FT-2312-30

Subsystem	Description	Logic	PFDavg	SIL (PF)	SC	SIL (AC)	MTTFS (y)
sensor	FT-30	2oo3	2,55E-05	4	3	3	3.714
sen_part	transmitter	--			3	--	--
sen_part	process	--				--	--
logicsolver	ESD-1	1oo2D	1,78E-04	3	3	3	167
actuator	[FG] XV-30/31	1oo2	1,95E-03	2	3	2	66
actuator	[NG] XV-32/33	1oo2	1,95E-03	2	3	2	66

Subsystem	Logic	Cpt	TI (y)	LT (y)	Beta	MTTRdd	Startup(h)	HFT	Type	Route
sensor		90%	1,00	15	5%	48	24	1	B	Route 1H
sen_part								1	B	
sen_part								1	A	
logicsolver		99%	4,00	15	2%	48	24	1	B	Route 1H
actuator		73%	1,00	15	10%	48	24	1	A	Route 1H
actuator		73%	1,00	15	10%	48	24	1	A	Route 1H

Subsystem	Description	Logic	SD	SU	DD	DU	SFF	DC
sensor	FT-30	2oo3	258	84	0	32	91%	
sen_part	transmitter	--	258	84	0	32		
sen_part	process	--	0	0	0	0		
logicsolver	ESD-1	1oo2D	12130	138	4082	256	98%	
actuator	[FG] XV-30/31	1oo2	0	916	0	829	52%	
actuator	[NG] XV-32/33	1oo2	0	916	0	829	52%	

Sensor DC calculation depends on sensor diagnostic set up.

SFF for Route 1H / DC for Routes 2H/IEC61511

DETAILED SIL VERIFICATION						Rev.1		20/08/2025																																																																																																																						
PROJECT NAME						Doc:																																																																																																																								
Sub-SIF M5-FT-2312-30																																																																																																																														
sub-SIF: Groups of ACTUATOR SUBSYSTEM used in other SIFs																																																																																																																														
<table><thead><tr><th>Subsystem</th><th>Description</th><th>SC</th><th>SD</th><th>SU</th><th>DD</th><th>DU</th><th>SFF</th><th>DC</th></tr></thead><tbody><tr><td>actuator</td><td>[FG] XV-30/31</td><td>3</td><td>0</td><td>916</td><td>0</td><td>829</td><td>52%</td><td></td></tr><tr><td>act_part</td><td>valve</td><td>3</td><td>0</td><td>0</td><td>0</td><td>442</td><td></td><td></td></tr><tr><td>act_part</td><td>actuator</td><td>3</td><td>0</td><td>286</td><td>0</td><td>199</td><td></td><td></td></tr><tr><td>act_part</td><td>solenoid</td><td>3</td><td>0</td><td>516</td><td>0</td><td>188</td><td></td><td></td></tr><tr><td>act_part</td><td>driver</td><td>3</td><td>0</td><td>114</td><td>0</td><td>0</td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr><tr><td>actuator</td><td>[NG] XV-32/33</td><td>3</td><td>0</td><td>916</td><td>0</td><td>829</td><td>52%</td><td></td></tr><tr><td>act_part</td><td>valve</td><td>3</td><td>0</td><td>0</td><td>0</td><td>442</td><td></td><td></td></tr><tr><td>act_part</td><td>actuator</td><td>3</td><td>0</td><td>286</td><td>0</td><td>199</td><td></td><td></td></tr><tr><td>act_part</td><td>solenoid</td><td>3</td><td>0</td><td>516</td><td>0</td><td>188</td><td></td><td></td></tr><tr><td>act_part</td><td>driver</td><td>3</td><td>0</td><td>114</td><td>0</td><td>0</td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr></tbody></table>										Subsystem	Description	SC	SD	SU	DD	DU	SFF	DC	actuator	[FG] XV-30/31	3	0	916	0	829	52%		act_part	valve	3	0	0	0	442			act_part	actuator	3	0	286	0	199			act_part	solenoid	3	0	516	0	188			act_part	driver	3	0	114	0	0												actuator	[NG] XV-32/33	3	0	916	0	829	52%		act_part	valve	3	0	0	0	442			act_part	actuator	3	0	286	0	199			act_part	solenoid	3	0	516	0	188			act_part	driver	3	0	114	0	0											
Subsystem	Description	SC	SD	SU	DD	DU	SFF	DC																																																																																																																						
actuator	[FG] XV-30/31	3	0	916	0	829	52%																																																																																																																							
act_part	valve	3	0	0	0	442																																																																																																																								
act_part	actuator	3	0	286	0	199																																																																																																																								
act_part	solenoid	3	0	516	0	188																																																																																																																								
act_part	driver	3	0	114	0	0																																																																																																																								
actuator	[NG] XV-32/33	3	0	916	0	829	52%																																																																																																																							
act_part	valve	3	0	0	0	442																																																																																																																								
act_part	actuator	3	0	286	0	199																																																																																																																								
act_part	solenoid	3	0	516	0	188																																																																																																																								
act_part	driver	3	0	114	0	0																																																																																																																								
Sensor DC calculation depends on sensor diagnostic set up.				SFF for Route 1H / DC for Routes 2H/IEC61511																																																																																																																										
Devices used in this SIF:																																																																																																																														
Floating Ball Valve, C series, Full Stroke, Clean Service																																																																																																																														
Actuator VL series, spring cylinder, Air-to-Retract																																																																																																																														
Solenoid series 327, De-energize to trip																																																																																																																														
DO interface, Solenoid Driver KFD0-SD-Ex 1																																																																																																																														
Floating Ball Valve, C series, Full Stroke, Clean Service																																																																																																																														
Actuator VL series, spring cylinder, Air-to-Retract																																																																																																																														
Solenoid series 327, De-energize to trip																																																																																																																														
DO interface, Solenoid Driver KFD0-SD-Ex 1																																																																																																																														

PROJECT NAME	Rev.1	20/08/2025
SIL VERIFICATION - LIST OF PRODUCTS	Doc:	

FAILURE RATES (FITS)										
Description	Vendor	Fail-High	Fail-Low	Fail-Detected	SD	SU	DD	DU	Type	SC
DEVICES OF SENSOR SUBSYSTEM										
3051 Pressure Transmitter (Coplanar Differential)	Emerson	24	27	207		84		32	B	3
IS Isolator AI/AI	P+F	28,50	143					44,50	A	2
1199 Remote Seal, High Trip, normal service	Rosemount							46	A	3
1199 Remote Seal, High Trip, severe service	Rosemount							76	A	3
Generic clean process connection	Generic								A	
3051 Pressure Transmitter (Coplanar Absolute)	Emerson	29	28	222		94		41	B	3
PT700 Pressure Transmitter	Honeywell	29	43	292		40		42	B	3
Absolute Pressure Switch series M, B, A, D, PC, PX	Ettore Cella					128		203	A	3
Generic Pressure Transmitter	Generic	115	300	115				450	B	PIU-2
Generic PT with credit by comparison	Generic				115		415	450	B	PIU-2
YTA710 Temperature Transmitter	Yokogawa	65	65	626		34		48	B	3
Generic RTD 2/3 wires	Generic	600	1000					400	A	3
DEVICES OF FINAL ELEMENTS										
Floating Ball Valve, C series, Full Stroke, Clean Service	Mogas							442	A	3
Floating Ball Valve, C series, Full Stroke, Severe Service	Mogas							809	A	3
Actuator VL series, spring cylinder, Air-to-Retract	Flowserve					286		199	A	3
Solenoid series 327, De-energize to trip	ASCO					516		188	A	3
DO interface, Solenoid Driver KFD0-SD-Ex 1	P+F					114			A	3
SAFETY PLC										
PLC: 1 AI, 1 DO	Generic				11617	129	3815	241	B	3
PLC: 1 AI, 2 DO same module	Generic				11756	130	3872	244	B	3
PLC: 2 AI, 2 DO same module	Generic				11804	133	3920	247	B	3
PLC: 3 AI, 2 DO same module	Generic				11852	136	3968	250	B	3
PLC: 3 AI, 4 DO same module	Generic				12130	138	4082	256	B	3
PLC: 1 DI, 2 DO same module	Generic				11412	154	3371	165	B	3